# RESULTS OF RADIOLOGICAL MEASUREMENTS AT 300 Lower Michigan Avenue CHICAGO, ILLINOIS

On:

MARCH 6, 2019

For:

# Member Mechanical, Inc. dba Burke Plumbing 6321 N Avondale Suite A 211 Chicago, ILLINOIS 60631

BY:

RSSI

6312 OAKTON STREET MORTON GROVE, ILLINOIS 60053

MARCH 21, 2019

#### Introduction

Member Mechanical, Inc. dba Burke Plumbing (Burke Plumbing) asked RSSI to perform surveys at 300 Lower Michigan Avenue as part of a utility replacement project. On March 6, 2019, RSSI surveyed the excavated area of the utility area. The purpose of these radiological measurements was to determine if there were radiation levels associated with thorium contamination.

Thorium-contaminated soils have been found at various locations in the Streeterville area of Chicago. Beginning in 1915, the Lindsay Light and Chemical Company (Lindsay Light) refined and used thorium in industrial operations between Illinois Street and Grand Avenue, east of Michigan Avenue. The Lindsay Light operation produced large volumes of thorium-contaminated tailings used as fill throughout Streeterville.

All isotopes of thorium are radioactive. Thorium's predominant isotopes are in the uranium and thorium decay series of naturally occurring radioactive isotopes. These series begin with uranium-238 (U-238) and thorium-232 (Th-232), respectively. Each series decays through a progression of radionuclides to a stable isotope of lead. The radionuclides include intermediate progeny, such as radium-226 (Ra-226) and radon-222 (Rn-222) in the uranium series and radium-228 (Ra-228), radium-224 (Ra-224), and radon-220 (Rn-220) in the thorium series as well as their decay products.

The EPA has set a concentration limit in soil of 5 picocuries per gram (pCi/g) total radium above background. Total radium is the sum of Ra-226 plus Ra-228. The EPA has stated that the background concentration in the Chicago Streeterville area is 2.1 pCi/g of total radium, resulting in an action level of 7.1 pCi/g total radium. The

guidelines permit release of areas for unrestricted use when the concentration of total radium in soil is no more than the action level.

### Methodology

RSSI measured radiation levels using a Ludlum Model 193 with an unshielded Ludlum Model 44-10 gamma scintillation detector. The Ludlum Model 193 is a general purpose portable survey instrument with a fixed-point alarm and a quick deviation alarm that is based on the rate of change in radiation levels. The quick deviation alarm enables detection of slight changes in radiation levels. The Ludlum Model 44-10 has a 2"×2" thallium-doped sodium iodide (NaI(Tl)) gamma scintillator that responds to photons. The Ludlum Model 44-10 detector was unshielded to expose it to the survey area as completely as possible. The instrument responses was approximately 500 counts per minute (cpm) per picocurie per gram (pCi/g) of total radium. For this configuration, the EPA's limit of 7.1 pCi/g total radium (5 pCi/g above a background total radium level of 2.1 pCi/g results) corresponds to approximately 3550 cpm above background.

# Results

The excavation site was located at 300 Lower Michigan Avenue around a red fire hydrant located through a gated area. The survey was performed after the excavation was complete. The area was broken up into two zones as shown in figure 1.




Figure 1. Excavation site with zones labeled

The first zone started at the fence line and extended approximately 6 feet into the street and was approximately 6 feet wide. The second zone was from the fence line to the wall, approximately 6 feet, and 4 feet wide. Each zone was surveyed by lowering the detector and taking the highest reading for each depth of 1, 2.5, and 4 feet. There was a slight restriction on the probes mobility at 2.5 and 4 foot depth due to the presence of a gas line. The second zone was surveyed without difficulties.

Full results are shown in Appendix A. Instrument calibration records are shown in Appendix B.

# **Conclusions**

No measurement exceeded the EPA's action level of 7.1 pCi/g total radium (5 pCi/g total radium plus local total radium background of 2.1 pCi/g).



# MARCH 6, 2019

Ludlum 193, SN 149080 Ludlum 44-10, "#2" 25', unshielded

Efficiency: 500 cpm/pCi/g (thorium) Action level: 3550 net cpm

Background: 1500 cpm Action level: 5050 gross cpm Check Source: 110000 cpm

Gross Counts(cpm)	Net Counts(cpm)	Total Radium (pCi/g)	Depth (ft)
2000	500	1	1
1600	100	0.2	2.5
1600	100	0.2	4
1200	0	0	1
1200	0	0	2.5
800	0	0	4



# CERTIFICATE OF CALIBRATION



6312 West Oakton Street Morton Grove, IL 60053-2723 Telephone: 847-965-1999 Fax: 847-965-1991

www.rssi.us

Certificate No. 051165

**RSSI** 

Attention: Eli A. Port. Rso

6312 Oakton Street

Morton Grove, IL 60053-2723

Manufacturer: LUDLUM

Model:

193

Serial No.:

149080

Probe(s):

LUDLUM 44-10, Sn: PR155592

#### CALIBRATION DATA

SOURCE*	SCALE	FIELD ( cpm )	READING ( cpm )	FIELD ( cpm )	READING (cpm)
5	x1	200	200	800	800
5	x10	2 K	2 K	8 K	8 K
5	x100	20 K	20 K	80 K	80 K
5	x1000	200 K	200 K	800 K	800 K

If the accuracy of a scale is not within +/-10% but is within +/-20% a correction factor is supplied.

LUDLUM 44-10 Efficiencies:

Shielded, 3' cable

γ: 660 cpm/pCi/g (Thorium)

γ: 640 cpm/pCi/g (Radium)

**LUDLUM 44-10 Efficiencies: LUDLUM 44-10 Efficiencies:** 

Unshielded, 3' cable Shielded, 25' cable

γ: 332 cpm/pCi/g (Thorium)

γ: 1820 cpm/pCi/g (Thorium) γ: 1820 cpm/pCi/g (Radium) γ: 332 cpm/pCi/g (Radium)

LUDLUM 44-10 Efficiencies:

Unshielded, 25' cable  $\gamma$ : 500 cpm/pCi/g (Thorium)

γ: 520 cpm/pCi/g (Radium)

Check Source: Ba-133

Reading: 297,400 net cpm Cable Length: 3'

Check Source: Ba-133

Reading: 118,800 net cpm Cable Length: 25'

Temperature:

22.5°C

Relative Humidity:

25 %

Barometric Pressure:

996 mbar

Comments:

Check source readings taken with label side facing detector.

Date: 03/26/18

Calibrated by:

Calibration Frequency:

Annual

Recalibrate by: 03/26/19

\*SOURCE Manufacturer Model Serial Number Activity

Date

1. Cs-137 U.S. Nuclear CCs-D-20E 69036EZ 15 Ci

4/2009

2. Cs-137 Eon Corp. 64-764 722 100 mCi 5/2/78

3. Am-241 Amersham AMC 13446 7510 LA 100 mCi

6/3/84

4. Cf-252 Amersham 100 FTC-CF-001 1801 μg

10/8/85

5. Electronic LUDLUM 500 32789

NONE

11/18/09

6. Other

Calibration authorized by Illinois Department of Nuclear Safety License No. IL-01429-01 and meets the requirements of ANSI 323-1978 and MIL-STD-45662A

Exposure rate traceable to NIST with MDH model 1015C, S.N. 2772 transfer instrument. Radcal Certificate of Conformance S116437.

# PREVENTIVE MAINTENANCE PERFORMED

BATTERIES/CONTACTS CHECKED	<b>√</b>	1.61 V, 1.61 V
HIGH VOLTAGE MEASURED	✓	880 VOLTS
SENSITIVITY MEASURED	<b>√</b>	10 mVOLTS
METER ZERO CHECKED	<b>√</b>	
INSTRUMENT CLEANED	<b>√</b>	

# **REPAIR AND PART INFORMATION**

Quantity	Description	
Repair Time:	hours	
Comments:		

Lab Reference: 55

Calibrated using the IEMA West Chicago blocks.