

3.1
39690

DRINKING WATER REGULATIONS AND HEALTH ADVISORIES

by

**Office of Water
U.S. Environmental Protection Agency
Washington, D.C.
202-260-7571**

**SAFE DRINKING WATER HOTLINE
1-800-426-4791
Monday thru Friday, 8:30 AM to 5:00 PM EST**

May 1994

300612

LEGEND

Abbreviations column descriptions are:

- MCLG - Maximum Contaminant Level Goal. A non-enforceable concentration of a drinking water contaminant that is protective of adverse human health effects and allows an adequate margin of safety.
- MCL - Maximum Contaminant Level. Maximum permissible level of a contaminant in water which is delivered to any user of a public water system.
- RfD - Reference Dose. An estimate of a daily exposure to the human population that is likely to be without appreciable risk of deleterious effects over a lifetime.
- DWEL - Drinking Water Equivalent Level. A lifetime exposure concentration protective of adverse, non-cancer health effects, that assumes all of the exposure to a contaminant is from a drinking water source.

(*) The codes for the Status Reg and Status HA columns are as follows:

- E - final
D - draft
L - listed for regulation
P - proposed
T - tentative

Other codes found in the table include the following:

- NA - not applicable
PS - performance standard 0.5 NTU - 1.0 NTU
TT - treatment technique
- ** - No more than 5% of the samples per month may be positive. For systems collecting fewer than 40 samples/month, no more than 1 sample per month may be positive.
- *** - guidance
- Large discrepancies between Lifetime and Longer-term HA values may occur because of the Agency's conservative policies, especially with regard to carcinogenicity, relative source contribution, and less than lifetime exposures in chronic toxicity testing. These factors can result in a cumulative UF (uncertainty factor) of 10 to 1000 when calculating a Lifetime HA.

Drinking Water Standards and Health Advisories

May 1994

Page 1

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁶ Cancer Risk			
ORGANICS															
Acenaphthene	-	-	-	F	-	-	-	-	0.06	-	-	-	-		
Acifluorfen	T	zero	-	F	2	2	0.1	0.4	0.013	0.4	-	0.1	B2		
Acrylamide	F	zero	TT	F	0.2	0.2	0.01	0.04	0.001	0.04	-	0.001	B2		
Acrylonitrile	T	zero	-	D	-	-	-	-	-	-	-	-	0.006		
Adipate (diethylhexyl)	F	0.4	0.4	-	20	20	20	60	0.6	20	0.4	3	C		
Alachlor	F	zero	0.002	F	0.1	0.1	-	-	0.01	0.4	-	0.04	B2		
Aldicarb	D	0.007	0.007	D	-	-	-	-	0.001	0.035	0.007	-	D		
Aldicarb sulfone	D	0.007	0.007	D	-	-	-	-	0.001	0.035	0.007	-	D		
Aldicarb sulfoxide	D	0.007	0.007	D	-	-	-	-	0.001	0.035	0.007	-	D		
Aldrin	-	-	-	D	0.0003	0.0003	0.0003	0.0003	0.00003	0.001	-	0.0002	B2		
Ametryn	-	-	-	F	9	9	0.9	3	0.009	0.3	0.06	-	D		
Ammonium sulfamate	-	-	-	F	20	20	20	80	0.28	8	2	-	D		
Anthracene (PAH)	-	-	-	-	-	-	-	-	0.3	-	-	-	D		
Atrazine	F	0.003	0.003	F	0.1	0.1	0.05	0.2	0.035	0.2*	0.003*	-	C		
Baygon	-	-	-	F	0.04	0.04	0.04	0.1	0.004	0.1	0.003	-	C		
Bentazon	T	0.02	-	F	0.3	0.3	0.3	0.9	0.0025	0.09	0.02	-	D		
Benz(a)anthracene (PAH)	P	zero	0.0001	-	-	-	-	-	-	-	-	-	B2		
Benzene	F	zero	0.005	F	0.2	0.2	-	-	-	-	-	0.1	A		
Benzo(a)pyrene (PAH)	F	zero	0.0002	-	-	-	-	-	-	-	-	-	B2*		
Benzo(b)fluoranthene (PAH)	P	zero	0.0002	-	-	-	-	-	-	-	-	-	B2		
Benzo(g,h,i)perylene (PAH)	-	-	-	-	-	-	-	-	-	-	-	-	D		
Benzo(k)fluoranthene (PAH)	P	zero	0.0002	-	-	-	-	-	-	-	-	-	B2		
bis-2-Chloroisopropyl ether	-	-	-	F	4	4	4	13	0.04	1	0.3	-	D		
Bromacil	L	-	-	F	5	5	3	9	0.13	5	0.09	-	C		
Bromobenzene	L	-	-	D	-	-	-	-	-	-	-	-	-		

* Under review.

NOTE: Anthracene and Benzo(g,h,i)perylene — not proposed in Phase V.

NOTE: Changes from the last version are noted in Italic and Bold Face print.

Drinking Water Standards and Health Advisories

May 1994

Page 2

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer-term (mg/l)	Longer-term (mg/l)	RfD (mg/kg/day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁴ Cancer Risk			
Bromochloroacetonitrile	L	-	-	D	-	-	-	-	-	-	-	-	-		
Bromochloromethane	-	-	-	F	50	1	1	5	0.013	0.5	0.09	-	-		
Bromodichloromethane (THM)	T zero	0.1*/0.08*	0.1*/0.08*	D	7	7	4	13	0.02	0.7	-	0.06	B2		
Bromoform (THM)	T zero	0.1*/0.08*	0.1*/0.08*	D	5	2	2	6	0.02	0.7	-	0.4	B2		
Bromomethane	T	-	-	F	0.1	0.1	0.1	0.5	0.001	0.04	0.01	-	D		
Butyl benzyl phthalate (PAE)	P zero	0.1	-	-	-	-	-	-	0.2	6	-	-	C		
Butylate	-	-	-	F	2	2	1	4	0.05	2	0.35	-	D		
Butylbenzene n-	-	-	-	D	-	-	-	-	-	-	-	-	-		
Butylbenzene sec-	-	-	-	D	-	-	-	-	-	-	-	-	-		
Butylbenzene tert-	-	-	-	D	-	-	-	-	-	-	-	-	-		
Carbaryl	-	-	-	F	1	1	1	1	0.1	4	0.7	-	D		
Carbofuran	F 0.04	0.04	-	F	0.05	0.05	0.05	0.2	0.005	0.2	0.04	-	E		
Carbon tetrachloride	F zero	0.005	-	F	4	0.2	0.07	0.3	0.0007	0.03	-	0.03	B2		
Carboxin	-	-	-	F	1	1	1	4	0.1	4	0.7	-	D		
Chloral hydrate	T 0.04	0.06**	-	D	7	1.4	0.2	0.6	0.0002	0.07	0.06	-	C		
Chloramben	-	-	-	F	3	3	0.2	0.5	0.015	0.5	0.1	-	D		
Chlordane	F zero	0.002	-	F	0.06	0.06	-	-	0.00006	0.002	-	0.003	B2		
Chlorodibromomethane (THM)	T 0.06	0.1*/0.08*	0.1*/0.08*	D	7	7	2	8	0.02	0.7	0.06	-	C		
Chloroethane	L	-	-	D	-	-	-	-	-	-	-	-	-		
Chloroform (THM)	T zero	0.1*/0.08*	0.1*/0.08*	D	4	4	0.1	0.4	0.01	0.4	-	0.6	B2		
Chloromethane	L	-	-	F	9	0.4	0.4	1	0.004	0.1	0.003	-	C		
Chlorophenol (2-)	-	-	-	D	0.05	0.05	0.05	0.2	0.005	0.2	0.04	-	D		
p-Chlorophenyl methyl sulfide/sulfone/sulfoxide	-	-	-	**	-	-	-	-	-	-	-	-	D		
Chloropicrin	L	-	-	-	-	-	-	-	-	-	-	-	-		
Chlorothalonil	-	-	-	F	0.2	0.2	0.2	0.5	0.015	0.5	-	0.15	B2		
Chlorotoluene o-	L	-	-	F	2	2	2	7	0.02	0.7	0.1	-	D		
Chlorotoluene p-	L	-	-	F	2	2	2	7	0.02	0.7	0.1	-	D		
Chlorpyrifos	-	-	-	F	0.03	0.03	0.03	0.1	0.003	0.1	0.02	-	D		
Chrysene (PAH)	P zero	0.0002	-	-	-	-	-	-	-	-	-	-	B2		
Cyanazine	T 0.001	-	-	D	0.1	0.1	0.02	0.07	0.002	0.07	0.001	-	C		

* Current MCL * Total for all THMs combined cannot exceed the 0.08 level. ** Total for all haloacetic acids cannot exceed 0.06 level.

• A HA will not be developed due to insufficient data; a "Database Deficiency Report has been published."

300615

Drinking Water Standards and Health Advisories

May 1994

Page 3

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁶ Cancer Risk			
Cyanogen chloride	L	-	-	-	-	-	-	-	-	-	-	-	-		
Cymene p-	-	-	-	D	-	-	-	-	-	-	-	-	-		
2,4-D	F	0.07	0.07	F	1	0.3	0.1	0.4	0.01	0.4	0.07	-	D		
DCPA (Dacthal)	L	-	-	F	80	80	5	20	0.5	20	4	-	D		
Dalapon	F	0.2	0.2	F	3	3	0.3	0.9	0.026	0.9	0.2	-	D		
Di[2-ethylhexyl]adipate	F	0.4	0.4	-	20	20	20	60	0.6	20	0.4	3	C		
Diazinon	-	-	-	F	0.02	0.02	0.005	0.02	0.00009	0.003	0.0006	-	E		
Dibenz(a,h)anthracene (PAH)	P	zero	0.0003	-	-	-	-	-	-	-	-	-	B2		
Dibromoacetonitrile	L	-	-	D	2	2	2	8	0.02	0.8	0.02	-	C		
Dibromochloropropane (DBCP)	F	zero	0.0002	F	0.2	0.05	-	-	-	-	-	0.003	B2		
Dibromomethane	L	-	-	-	-	-	-	-	-	-	-	-	D		
Dibutyl phthalate (PAE)	-	-	-	-	-	-	-	-	0.1	4	-	-	D		
Dicamba	L	-	-	F	0.3	0.3	0.3	1	0.03	1	0.2	-	D		
Dichloroacetaldehyde	L	-	-	D	-	-	-	-	-	-	-	-	-		
Dichloroacetic acid	T	zero	0.06**	D	1	1	1	4	0.004	0.1	-	-	B2		
Dichloroacetonitrile	L	-	-	D	1	1	0.8	3	0.008	0.3	0.006	-	C		
Dichlorobenzene o-	F	0.6	0.6	F	9	9	9	30	0.09	3	0.6	-	D		
Dichlorobenzene m-	F	0.6	0.6	F	9	9	9	30	0.09	3	0.6	-	D		
Dichlorobenzene p-	F	0.075	0.075	F	10	10	10	40	0.1	4	0.075	-	C		
Dichlorodifluoromethane	L	-	-	F	40	40	9	30	0.2	5	1	-	D		
Dichloroethane (1,1-)	L	-	-	D	-	-	-	-	-	-	-	-	-		
Dichloroethane (1,2-)	F	zero	0.005	F	0.7	0.7	0.7	2.6	-	-	-	0.04	B2		
Dichloroethylene (1,1-)	F	0.007	0.007	F	2	1	1	4	0.009	0.4	0.007	-	C		
Dichloroethylene (cis-1,2-)	F	0.07	0.07	F	4	3	3	11	0.01	0.4	0.07	-	D		
Dichloroethylene (trans-1,2-)	F	0.1	0.1	F	20	2	2	6	0.02	0.6	0.1	-	D		
Dichloromethane	F	zero	0.005	F	10	2	-	-	0.06	2	-	0.5	B2		
Dichlorophenol (2,4-)	-	-	-	D	0.03	0.03	0.03	0.1	0.003	0.1	0.02	-	D		
Dichloropropane (1,1-)	-	-	-	D	-	-	-	-	-	-	-	-	-		
Dichloropropane (1,2-)	F	zero	0.005	F	-	0.09	-	-	-	-	-	0.05	B2		
Dichloropropane (1,3-)	L	-	-	D	-	-	-	-	-	-	-	-	-		

* The values for m-dichlorobenzene are based on data for o-dichlorobenzene.

** Total for all haloacetic acids cannot exceed 0.06 level.

300616

Drinking Water Standards and Health Advisories

May 1994

Page 4

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁶ Cancer Risk			
Dichloropropane (2,2-)	L	-	-	D	-	-	-	-	-	-	-	-	-		
Dichloropropene (1,1-)	L	-	-	D	-	-	-	-	-	-	-	-	-		
Dichloropropene (1,3-)	T	zero	-	F	0.03	0.03	0.03	0.09	0.0003	0.01	-	0.02	B2		
Dieldrin	-	-	-	F	0.0005	0.0005	0.0005	0.002	0.00005	0.002	-	0.0002	B2		
Diethyl phthalate (PAE)	-	-	-	D	-	-	-	0.8	30	5	-	-	D		
Diethylene glycol dinitrate	-	-	-	**	-	-	-	-	-	-	-	-	-		
Diethylhexyl phthalate (PAE)	F	zero	0.006	D	-	-	-	0.02	0.7	-	0.3	-	B2*		
Disopropyl methylphosphonate	-	-	-	F	8	8	8	30	0.08	3	0.6	-	D		
Dimethrin	-	-	-	F	10	10	10	40	0.3	10	2	-	D		
Dimethyl methylphosphonate	-	-	-	F	2	2	2	6	0.2	7	0.1	0.7	C		
Dimethyl phthalate (PAE)	-	-	-	-	-	-	-	-	-	-	-	-	D		
1,3-Dinitrobenzene	-	-	-	F	0.04	0.04	0.04	0.14	0.0001	0.005	0.001	-	D		
Dinitrotoluene (2,4-)	L	-	-	F	0.50	0.50	0.30	1	0.002	0.1	-	-	-		
Dinitrotoluene (2,6-)	L	-	-	F	0.40	0.40	0.40	1	0.001	0.04	-	-	-		
tg 2,6 & 2,4 dinitrotoluene ***	-	-	-	-	-	-	-	-	-	-	-	0.005	B2		
Dinoseb	F	0.007	0.007	F	0.3	0.3	0.01	0.04	0.001	0.04	0.007	-	D		
Dioxane p-	-	-	-	F	4	0.4	-	-	-	-	-	0.7	B2		
Diphenamid	-	-	-	F	0.3	0.3	0.3	1	0.03	1	0.2	-	D		
Diphenylamine	-	-	-	F	1	1	0.3	1	0.03	1	0.2	-	D		
Diquat	F	0.02	0.02	-	-	-	-	-	0.0022	0.08	0.02	-	D		
Disulfoton	-	-	-	F	0.01	0.01	0.003	0.009	0.00004	0.001	0.0003	-	E		
Dithiane (1,4-)	-	-	-	F	0.4	0.4	0.4	1	0.01	0.4	0.08	-	D		
Diuron	-	-	-	F	1	1	0.3	0.9	0.002	0.07	0.01	-	D		
Endothall	F	0.1	0.1	F	0.8	0.8	0.2	0.2	0.02	0.7	0.1	-	D		
Endrin	F	0.002	0.002	F	0.02	0.02	0.003	0.01	0.0003	0.01	0.002	-	D		
Epichlorohydrin	F	zero	TT	F	0.1	0.1	0.07	0.07	0.002	0.07	-	0.4	B2		
Ethylbenzene	F	0.7	0.7	F	30	3	1	3	0.1	3	0.7	-	D		
Ethylene dibromide (EDB)	F	zero	0.00005	F	0.008	0.008	-	-	-	-	-	0.00004	B2		
Ethylene glycol	-	-	-	F	20	6	6	20	2	40	7	-	D		
ETU	L	-	-	F	0.3	0.3	0.1	0.4	0.00008	0.003	-	0.03	B2		
Fenamiphos	-	-	-	F	0.009	0.009	0.005	0.02	0.00025	0.009	0.002	-	D		

* Under review. ** A HA will not be developed due to insufficient data; a "Database Deficiency Report" has been published.

Drinking Water Standards and Health Advisories

May 1994

Page 5

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁴ Cancer Risk			
Fluometron	-	-	-	F	2	2	2	5	0.013	0.4	0.09	-	D		
Fluorene (PAH)	-	-	-	-	-	-	-	-	0.04	-	-	-	D		
Fluorotrichloromethane	L	-	-	F	7	7	3	10	0.3	10	2	-	D		
Fog Oil	-	-	-	D	-	-	-	-	-	-	-	-	-		
Fonofos	-	-	-	F	0.02	0.02	0.02	0.07	0.002	0.07	0.01	-	D		
Formaldehyde	-	-	-	D	10	5	5	20	0.15	5	1	-	B1		
Gasoline, unleaded (benzene)	-	-	-	D	-	-	-	-	-	-	0.005	-	-		
Glyphosate	F	0.7	0.7	F	20	20	1	1	0.1	4	0.7	-	E		
Heptachlor	F	zero	0.0004	F	0.01	0.01	0.005	0.005	0.0005	0.02	-	0.0008	B2		
Heptachlor epoxide	F	zero	0.0002	F	0.01	-	0.0001	0.0001	1E-5	0.0004	-	0.0004	B2		
Hexachlorobenzene	F	zero	0.001	F	0.05	0.05	0.05	0.2	0.0008	0.03	-	0.002	B2		
Hexachlorobutadiene	T	0.001	-	F	0.3	0.3	0.1	0.4	0.002	0.07	0.001	-	C		
Hexachlorocyclopentadiene	F	0.05	0.05	-	-	-	-	-	0.007	0.2	-	-	D		
Hexachloroethane	L	-	-	F	5	5	0.1	0.5	0.001	0.04	0.001	-	C		
Hexane (n-)	-	-	-	F	10	4	4	10	-	-	-	-	D		
Hexazinone	-	-	-	F	3	3	3	9	0.033	1	0.2	-	D		
HMX	-	-	-	F	5	5	5	20	0.05	2	0.4	-	D		
Indeno(1,2,3,-c,d)pyrene (PAH)	P	zero	0.0004	D	-	-	-	-	-	-	-	-	B2		
Isophorone	L	-	-	F	15	15	15	15	0.2	7	0.1	4	C		
Isopropyl methylphosphonate	-	-	-	D	30	30	30	100	0.1	4.0	0.7	-	D		
Isopropylbenzene	-	-	-	D	-	-	-	-	-	-	-	-	-		
Lindane	F	0.0002	0.0002	F	1	1	0.03	0.1	0.0003	0.01	0.0002	-	C		
Malathion	-	-	-	F	0.2	0.2	0.2	0.8	0.02	0.8	0.2	-	D		
Maleic hydrazide	-	-	-	F	10	10	5	20	0.5	20	4	-	D		
MCPA	-	-	-	F	0.1	0.1	0.1	0.4	0.0015	0.05	0.01	-	E		
Methomyl	L	-	-	F	0.3	0.3	0.3	0.3	0.025	0.9	0.2	-	D		
Methoxychlor	F	0.04	0.04	F	0.05	0.05	0.05	0.2	0.005	0.2	0.04	-	D		
Methyl ethyl ketone	-	-	-	F	-	-	-	-	-	-	-	-	-		
Methyl parathion	-	-	-	F	0.3	0.3	0.03	0.1	0.00025	0.009	0.002	-	D		

* Under review.

31900

Drinking Water Standards and Health Advisories

May 1994

Page 6

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁴ Cancer Risk			
Methyl tert butyl ether	L	-	-	D	3	3	0.5	2	0.005	0.2	0.04	-	D		
Metolachlor	L	-	-	F	2	2	2	5	0.15	5	0.1	-	C		
Metribuzin	L	-	-	F	5	5	0.3	0.9	0.025	0.9	0.2	-	D		
Monochloroacetic acid	L	-	-	D	-	-	-	-	-	-	-	-	1		
Monochlorobenzene	F	0.1	0.1	F	2	2	2	7	0.02	0.7	0.1	-	D		
Naphthalene	-	-	-	F	0.5	0.5	0.4	1	0.004	0.1	0.02	-	D		
Nitrocellulose (non-toxic)	-	-	-	F	-	-	-	-	-	-	-	-	-		
Nitroguanidine	-	-	-	F	10	10	10	40	0.1	4	0.7	-	D		
Nitrophenol p-	-	-	-	F	0.8	0.8	0.8	3	0.008	0.3	0.06	-	D		
Oxamyl (Vydate)	F	0.2	0.2	F	0.2	0.2	0.2	0.9	0.025	0.9	0.2	-	E		
Paraquat	-	-	-	F	0.1	0.1	0.05	0.2	0.0045	0.2	0.03	-	E		
Pentachloroethane	-	-	-	D	-	-	-	-	-	-	-	-	2		
Pentachlorophenol	F	zero	0.001	F	1	0.3	0.3	1	0.03	1	-	0.03	B2		
Phenanthrene (PAH)	-	-	-	D	6	6	6	20	0.6	20	4	-	D		
Phenol	-	-	-	F	20	20	0.7	2	0.07	2	0.5	-	D		
Picloram	F	0.5	0.5	F	-	-	-	-	-	-	-	-	D		
Polychlorinated biphenyls (PCBs)	F	zero	0.0005	P	-	-	-	-	-	-	-	0.0005	B2		
Prometon	L	-	-	F	0.2	0.2	0.2	0.5	0.015*	0.5*	0.1*	-	D		
Pronamide	-	-	-	F	0.8	0.8	0.8	3	0.075	3	0.05	-	C		
Propachlor	-	-	-	F	0.5	0.5	0.1	0.5	0.013	0.5	0.09	-	D		
Propazine	-	-	-	F	1	1	0.5	2	0.02	0.7	0.01	-	C		
Propham	-	-	-	F	5	5	5	20	0.02	0.6	0.1	-	D		
Propylbenzene n-	-	-	-	D	-	-	-	-	-	-	-	-	-		
Pyrene (PAH)	-	-	-	-	-	-	-	-	0.03	-	-	-	D		
RDX	-	-	-	F	0.1	0.1	0.1	0.4	0.003	0.1	0.002	0.03	C		
Simazine	-	F	0.004	0.004	F	0.07	0.07	0.07	0.07	0.005	0.2	0.004	-	C	
Styrene	-	F	0.1	0.1	F	20	2	2	7	0.2	7	0.1	-	C	
2,4,5-T	L	-	-	F	0.8	0.8	0.8	1	0.01	0.35	0.07	-	D		
2,3,7,8-TCDD (Dioxin)	-	F	zero	3E-08	F	1E-06	1E-07	1E-08	4E-08	1E-09	4E-08	-	2E-08	B2	

* Under review. NOTE: Phenanthrene — not proposed.

300619

Drinking Water Standards and Health Advisories

May 1994

Page 7

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁴ Cancer Risk			
Tebuthiuron	-	-	-	F	3	3	0.7	2	0.07	2	0.5	-	D		
Terbacil	-	-	-	F	0.3	0.3	0.3	0.9	0.013	0.4	0.09	-	E		
Terbufos	-	-	-	F	0.005	0.005	0.001	0.005	0.00013	0.005	0.0009	-	D		
Tetrachloroethane (1,1,1,2-)	L	-	-	F	2	2	0.9	3	0.03	1	0.07	0.1	C		
Tetrachloroethane (1,1,2,2-)	L	-	-	D	-	-	-	-	-	-	-	-	-		
Tetrachloroethylene	F	zero	0.005	F	2	2	1	5	0.01	0.5	-	0.07	-		
Tetranitromethane	-	-	-	**	-	-	-	-	-	-	-	-	-		
Toluene	F	1	1	F	20	2	2	7	0.2	7	1	-	D		
Toxaphene	F	zero	0.003	F	0.5	0.04	-	-	0.1	0.0035	-	0.003	B2		
2,4,5-TP	F	0.05	0.05	F	0.2	0.2	0.07	0.3	0.0075	0.3	0.05	-	D		
1,1,2-Trichloro-1,2,2-trifluoroethane	-	-	-	-	-	-	-	-	-	-	-	-	-		
Trichloroacetic acid	T	0.3	0.06++	D	4	4	4	13	0.1	4.0	0.3	-	C		
Trichloroacetonitrile	L	-	-	D	0.05	0.05	-	-	-	-	-	-	-		
Trichlorobenzene (1,2,4-)	F	0.07	0.07	F	0.1	0.1	0.1	0.5	0.01	0.4	0.07	-	D		
Trichlorobenzene (1,3,5-)	-	-	-	F	0.6	0.6	0.6	2	0.006	0.2	0.04	-	D		
Trichloroethane (1,1,1-)	F	0.2	0.2	F	100	40	40	100	0.035	1	0.2	-	D		
Trichloroethane (1,1,2-)	F	0.003	0.005	F	0.6	0.4	0.4	1	0.004	0.1	0.003	-	C		
Trichloroethanol (2,2,2-)	L	-	-	-	-	-	-	-	-	-	-	-	-		
Trichloroethylene	F	zero	0.005	F	-	-	-	-	-	0.3	-	0.3	B2		
Trichlorophenol (2,4,6-)	L	-	-	D	-	-	-	-	-	-	-	0.3	B2		
Trichloropropane (1,1,1-)	-	-	-	D	-	-	-	-	-	-	-	-	-		
Trichloropropane (1,2,3-)	L	-	-	F	0.6	0.6	0.6	2	0.006	0.2	0.04	-	B2		
Trifluralin	L	-	-	F	0.08	0.08	0.08	0.3	0.0075	0.3	0.005	0.5	C		
Trimethylbenzene (1,2,4-)	-	-	-	D	-	-	-	-	-	-	-	-	-		
Trimethylbenzene (1,3,5-)	-	-	-	D	-	-	-	-	-	-	-	-	-		
Trinitroglycerol	-	-	-	F	0.005	0.005	0.005	0.005	-	-	0.005	-	-		
Trinitrotoluene	-	-	-	F	0.02	0.02	0.02	0.02	0.0005	0.02	0.002	0.1	C		
Vinyl chloride	F	zero	0.002	F	3	3	0.01	0.05	-	-	-	0.0015	A		
Xylenes	F	10	10	F	40	40	40	100	2	60	10	-	D		

** A HA will not be developed due to insufficient data; a "Database Deficiency Report" has been published.

++ Total for all haloacetic acids cannot exceed 0.06 level.

029000

Drinking Water Standards and Health Advisories

May 1994

Page 8

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁴ Cancer Risk			
INORGANICS															
Aluminum	L	-	-	D	-	-	-	-	-	-	-	-	-		
Ammonia	-	-	-	D	-	-	-	-	-	-	30	-	D		
Antimony	F	0.006	0.006	F	0.01	0.01	0.01	0.015	0.0004	0.01	0.003	-	D		
Arsenic	-	-	0.05	D	-	-	-	-	-	-	-	0.002	A		
Asbestos (fibers/l > 10µm length)	F	7 MFL	7 MFL	-	-	-	-	-	-	-	-	700 MFL	A		
Barium	F	2	2	F	-	-	-	-	0.07	2	2	-	D		
Beryllium	F	0.004	0.004	D	30	30	4	20	0.005	0.2	-	0.0008	B2		
Boron	L	-	-	D	4	0.9	0.9	3	0.09	3	0.6	-	D		
Bromate	L	zero	0.01	-	-	-	-	-	-	-	-	-	-		
Cadmium	F	0.005	0.005	F	0.04	0.04	0.005	0.02	0.0005	0.02	0.005	-	D		
Chloramine	T	4***	4	D	1	1	1	1	0.1	3.3	3/4***	-	-		
Chlorate	L	-	-	D	-	-	-	-	-	-	-	-	-		
Chlorine	T	4	4	D	-	-	-	-	0.08	-	-	-	D		
Chlorine dioxide	T	0.3	0.8	D	-	-	-	-	0.01	0.35	0.3	-	D		
Chlorite	L	0.08	1	D	-	-	-	-	0.003	0.1	0.08	-	D		
Chromium (total)	F	0.1	0.1	F	1	1	0.2	0.8	0.005	0.2	0.1	-	D		
Copper	F	1.3	TT**	-	-	-	-	-	-	-	-	-	D		
Cyanide	P	0.2	0.2	F	0.2	0.2	0.2	0.8	0.022	0.8	0.2	-	D		
Fluoride*	F	4	4	-	-	-	-	-	0.12	-	-	-	-		
Hypochlorite	T	4 [†]	-	-	-	-	-	-	-	-	-	-	-		
Hypochlorous acid	T	4 [†]	-	-	-	-	-	-	-	-	-	-	-		
Lead (at tap)	F	zero	TT**	-	-	-	-	-	-	-	-	-	B2		
Manganese	L	-	-	D	-	-	-	-	0.14/ 0.005	-	-	-	-		
Mercury (inorganic)	F	0.002	0.002	F	-	-	-	0.002	0.0003	0.01	0.002	-	D		
Molybdenum	L	-	-	D	-	0.08	0.01	0.05	0.005	0.2	0.04	-	D		
Nickel	F	0.1	0.1	F	1	1	0.5	1.7	0.02	0.6	0.1	-	D		
Nitrate (as N)	F	10	10	F	-	10*	-	-	1.6	-	-	-	-		

* Under review. ** Copper — action level 1.3 mg/L; Lead - action level 0.015 mg/L. *** Measured as free chlorine. [†] Regulated as chlorine.

30991

Drinking Water Standards and Health Advisories

May 1994

Page 9

Chemicals	Standards			Status HA	Health Advisories								Cancer Group		
	Status Reg.	MCLG (mg/l)	MCL (mg/l)		10-kg Child			70-kg Adult							
					One-day (mg/l)	Ten-day (mg/l)	Longer- term (mg/l)	Longer- term (mg/l)	RfD (mg/kg/ day)	DWEL (mg/l)	Lifetime (mg/l)	mg/l at 10 ⁻⁴ Cancer Risk			
Nitrite (as N)	F	1	1	F	-	1*	-	-	0.16*	-	-	-	*		
Nitrate + Nitrite (both as N)	F	10	10	F	-	-	-	-	-	-	-	-	*		
Selenium	F	0.05	0.05	-	-	-	-	-	0.005	-	-	-	-		
Silver	-	-	-	D	0.2	0.2	0.2	0.2	0.005	0.2	0.1	-	D		
Sodium	-	-	-	D	-	-	-	-	-	20***	-	-	-		
Strontium	L	-	-	D	25	25	25	90	0.6	90	17	-	D		
Sulfate	P	**	**	-	-	-	-	-	-	-	-	-	-		
Thallium	F	0.0005	0.002	F	0.007	0.007	0.007	0.02	0.00007	0.002	0.0004	-	-		
Vanadium	L	-	-	D	-	-	-	-	-	-	-	-	D		
White phosphorous	-	-	-	F	-	-	-	-	0.00002	0.0005	0.0001	-	D		
Zinc	L	-	-	F	6	6	3	12	0.3	11	2	-	D		
Zinc chloride (measured as Zinc)	L	-	-	F	6	6	3	12	0.3	11	2	-	D		
RADIONUCLIDES															
Beta particle and photon activity (formerly man-made radionuclides)	P	zero	4 mrem	-	-	-	-	-	-	-	-	-	4 mremly		
Gross alpha particle activity	P	zero	15 pCi/L	-	-	-	-	-	-	-	-	-	A		
Radium 226	P	zero	20 pCi/L	-	-	-	-	-	-	-	-	-	15 pCi/L		
Radium 228	P	zero	20 pCi/L	-	-	-	-	-	-	-	-	-	20 pCi/L		
Radon	P	zero	300 pCi/L	-	-	-	-	-	-	-	-	-	20 pCi/L		
Uranium	P	zero	20 µg/L	-	-	-	-	-	0.003	-	-	-	150 pCi/L		

* Under review.

** Deferred.

*** Guidance.

300682

Microbiology

May 1994

Page 11

	Status	MCLG	MCL
Cryptosporidium	L	-	-
<i>Giardia lamblia</i>	F	zero	TT
Legionella	F ^a	zero	TT
Standard Plate Count	F ^a	NA	TT
Total Coliforms (after 12/31/90)	F	zero	**
Turbidity (after 12/31/90)	F	NA	PS
Viruses	F ^a	zero	TT

Key: PS, TT, F, defined as previously stated.

^a Final for systems using surface water; also being considered for regulation under groundwater disinfection rule.

300623