

*Also State Boilers*  
HARTFORD STEAM BOILER  
INSPECTION & INSURANCE CO.

147471



THE HARTFORD STEAM BOILER  
INSPECTION and INSURANCE COMPANY  
HARTFORD • CONNECTICUT 06102

CLEVELAND OFFICE—610 EUCLID AVENUE, CLEVELAND, OHIO 44114—(216) 781-4811

July 21, 1971

Chemical Service Company  
128 Locust Street  
Elyria, Ohio 44035

Your following listed insured equipment located at 128 Locust Street, Elyria, Ohio 44035 was inspected by Inspector G. Javor on July 7, 1971 and no conditions were observed that require attention at this time.

Sellers Fire Tube H. T. Boiler No. 133266

Yours very truly,

*H. E. Granstad*

Chief Inspector

JEM:M

July 14, 1969

The Hartford Steam Boiler Ins. Co.  
610 Euclid Ave.  
Cleveland, Ohio 44114

Attention: Mr. W.B. Mount

Dear Mr. Mount,

I am in receipt of your letter dated July 11, 1969, but am at a loss to understand what you are talking about. In the first place, I received a bill from you April 11, 1969, for this insurance coverage from Nov. 11, 1968 to April 21, 1969, in the amount of \$43.00. I wonder how it grew to \$55.00 as stated in your letter. Secondly, I did not renew this insurance, so I wonder why I received a bill at all. When Mr. Iglaur called me last November, and said I would have to pay this premium or the insurance would be cancelled, I told him I could not afford to pay it at that time, so if he had to cancel it, he should do what he must.

I also do not understand what you mean by saying if you do not receive our check within 10 days, you will cancel all of our coverage. Sir, we do not have any other coverage with you. If you are by any chance referring to Obitts Chemical Co., located next door to us, I assure you we are an entirely different corporation, with different stockholders, and officers. That would be like you telling me you are going to use my insurance credit to pay Harshaw Chemical's insurance bill because they are across the street from me.

If you wish to check into this matter further, you may contact our attorney who is also the secretary of this corporation. His name is Joseph Cirigliano, Citizen's Home and Savings Assn. Co., Building, Lorain, Ohio.

Very truly yours,

Chemical Service Corporation

Dorothy Obitts, Treas.

do/dd



THE HARTFORD STEAM BOILER  
INSPECTION and INSURANCE COMPANY  
HARTFORD • CONNECTICUT 06102

WILLIAM B. MOUNT  
*Manager*

L. E. GRAMSTAD  
*Chief Inspector*  
July 11, 1969

CLEVELAND OFFICE

610 EUCLID AVENUE  
CLEVELAND, OHIO 44114  
781-4811

Chemical Service Corporation  
P. O. Box 375  
Elyria, Ohio

Attention: Mr. Obitz:

Dear Mr. Obitz:

Coverage under Policy No. 89-3939 remained in force from November 11, 1968 through April 21, 1969 without any payment of premium by Chemical Service Corporation.

Several months ago, I discussed this situation with you by telephone, and you agreed to pay the earned premium for this period which amounted to \$55.00. About eight weeks later, our bookkeeper contacted you and again payment was promised, but to date we have not received your check for this amount which is long overdue and which must be cleared from our books.

In the event that we do not receive your check within the next ten days, it will be necessary for us to cancel all of your coverage in order to clear this account. We sincerely hope that these steps will not be necessary, but I'm sure you're aware of the importance of proper and prompt payment of these outstanding items - especially when the earned premium is so small. I will look forward to receipt of your check at an early date. Thank you for your attention to this matter.

Very truly yours,  
*Bill Mount*  
W. B. Mount, Manager

*Please*

WBM:ew

cc: Louis B. Iglauer  
410 Hanna Bldg., Cleveland, Ohio



THE HARTFORD STEAM BOILER  
INSPECTION and INSURANCE COMPANY  
HARTFORD • CONNECTICUT 06102

CLEVELAND OFFICE  
610 EUCLID AVENUE  
CLEVELAND, OHIO 44114

Chemical Service Corp.  
P.O. Box 375  
Elyria, Ohio 44035  
Attn: Mr. Obitts

April 11, 1969

Check should be drawn to the order of the Company

Date	Item	Amount	
4-21-69	Policy No. 89-3939  CHEMICAL SERVICE CORP.  <i>Checks may be made payable to H. S. B. Co.</i>	43	00

DEPARTMENT OF INDUSTRIAL RELATIONS  
DIVISION OF BOILER INSPECTION  
220 Parsons Ave., Columbus, Ohio 43215



N<sup>o</sup> 60110  
REMIT Fee Amount \$6.00

**Application for Renewal of CERTIFICATE OF OPERATION**

Type **HT** Size **36" - 9'** Standard No. **NB 876** Boiler No. **133266** Maximum Pressure **150** PSI  
Location of Boiler **128 Locust St., Elyria, Ohio** Date Issued \_\_\_\_\_ Expires **July 31, 1970**

Owner and/or User

**Chemical Service Company  
P. O. Box 375  
Elyria, Ohio**

*pd. 6/10/69  
Chk. # 1020*

Last Insp. **6/10/68**

The Certificate of Operation for the boiler indicated above will expire July 31st. The boiler has been inspected and approved for renewal of the Certificate. Return one copy of this application together with the fee of \$6.00 and the certificate will be mailed to you.

**RETURN ONE COPY WITH REMITTANCE—MAKE PAYABLE TO TREASURER OF STATE**

**CANCELATION NOTICE**

**THE HARTFORD STEAM BOILER INSPECTION AND INSURANCE COMPANY**  
Hartford, Connecticut

April 9, 1969

CHEMICAL SERVICE CORP.

P.O. Box 375

Elyria, Ohio 44035

Please take notice that, in accordance with the terms and conditions of Policy No. 89-3939 issued to you by The Hartford Steam Boiler Inspection and Insurance Company, the said policy is hereby canceled as of noon of April 21, 1969.

The return of any premium paid for this insurance will be made in accordance with the policy provisions.

Countersigned

*A. Rugh*

Authorized Representative

*L.B. Brained*  
President



THE HARTFORD STEAM BOILER  
INSPECTION and INSURANCE COMPANY  
HARTFORD • CONNECTICUT 06102

WILLIAM B. MOUNT  
*Manager*

L. E. GRAMSTAD  
*Chief Inspector*

CLEVELAND OFFICE  
610 EUCLID AVENUE  
CLEVELAND, OHIO 44114

June 28, 1968

REPORT OF INSPECTION

DATE OF INSPECTION June 10, 1968

LOCATION 128 Locust St., Elyria, Ohio 44035

INSPECTOR G.M. Javor

Your insured boiler was inspected on the above date and no conditions were observed that require attention at this time.


Very truly yours,

*L. E. Gramstad*  
Chief Inspector

JFM:kae:89

TO  
Chemical Service Corporation  
P.O. Box 375  
Elyria, Ohio





THE HARTFORD STEAM BOILER  
INSPECTION and INSURANCE COMPANY  
HARTFORD • CONNECTICUT 06102

WILLIAM B. MOUNT  
*Manager*

L. E. GRAMSTAD  
*Chief Inspector*

CLEVELAND OFFICE

610 EUCLID AVENUE  
CLEVELAND, OHIO 44114

November 3, 1967

LOCATION 128 Locust St., Elyria, Ohio

INSPECTED October 30, 1967

Our Inspector visited your plant on the above date for the purpose of examining insured equipment. The inspection revealed no conditions requiring attention at this time.

Very truly yours,

*L. E. Gramstad*  
Chief Inspector

LEG/gl

To

Chemical Service Co.  
P.O.Box 375  
Elyria, Ohio

January 27, 1966

**The Hartford Steam Boiler and  
Insurance Company  
610 Euclid Avenue  
Cleveland, Ohio 44114**

Dear Sir,

Your inspector, Mr. G.M. Javor recently inspected our new boiler. He took with him our specification sheet on this boiler. If you are finished with it, we would appreciate having it back as we need it for reference.

Thank you for your inconvenience.

Very truly yours,

**Chemical Service Corporation**



**Dorothy K. Dubena, Treasurer**

## THE HARTFORD STEAM BOILER INSPECTION AND INSURANCE COMPANY

## MEMORANDUM

Date 2/1/66To Mr. Russ AbellFrom Geo. M. JoorSubject New Sp. Water Sheet & etc

---

*Attached are Water Reports*

*Thanks.*

---

# The Great Lakes Welding & Boiler Co.

Boilermakers and Welding Contractors

NEW AND USED BOILERS  
WELDED TANKS-CONTAINERS, ETC.

2000 HAMILTON AVENUE  
CLEVELAND 14, OHIO  
TELEPHONE: PROSPECT 1-5865

Dec. 2nd 1965

Obitts Chemical Co  
142 Locust st.,  
Elyria, O.,

Gentlemen:

Attention: Mr. Obitts

Enclosed please find Manufacturer's Data report on  
the new 50 HP Sella boiler you recently purchased  
from us.

This boiler carries Manufacturer's Serial #2872 and  
Nat'l Board Code #876.

Please file this data report for reference in the  
future either by your Insurance boiler inspector  
or anyone interested in this piece of equipment.

Very truly yours,



C. R. BOLEK

hw

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE  
As Required by the Provisions of the ASME Code Rules

1. Manufactured by Sellers Engineering Company - Danville, Kentucky  
(Name and address of manufacturer)

2. Manufactured for Stock Great Lakes Welding & Boiler Co., 2000 Hamilton Avenue, Cleveland, Ohio  
Horiz. Internal Gas  
(Name and address of purchaser)

3. Type Fired Steam Boiler Boiler No. 2872 876 Year Built 1965  
(H.R.T.--Loco.--Compact--Marine, Miniature) (Mfrs. Serial No.) (State and State No.) (Nat'l. Board No.)

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section I  
(I or IV)

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: UBM #6686  
(Name of Part - Item number, manufacturer's name, and identifying stamp)

Boiler shell postweld heat treated per PW-39

We certify the statement in this data report to be correct.

Date 10-22, 19 65 Signed Sellers Engineering Co. By [Signature]  
(Manufacturer) (Representative)

Certificate of Authorization Expires 12/31 19 67

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Sellers Engineering Company at Danville, Kentucky

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Conn.  
The Hartford Steam Boiler  
and employed by Inspection & Insurance Company of Hartford, Conn.  
have inspected parts of this boiler referred to as data items 11 and 24 and have examined manufacturer's partial data reports for items 5, 6, 7, 10, 20 and 22  
and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10-22, 19 65 Ky-54  
[Signature] Commissions NB 4343 - Ohio 1498 - PA-WC932 - Ind 329  
Inspector Nat'l Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND PRESSURE VESSEL CODE.

Date \_\_\_\_\_, 19 \_\_\_\_\_ Signed \_\_\_\_\_ By \_\_\_\_\_  
(Assembler) (Representative)

Our Certificate of Authorization to use the \_\_\_\_\_ Symbol Expires \_\_\_\_\_ 19 \_\_\_\_\_  
(A) or (S)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of \_\_\_\_\_ and employed by \_\_\_\_\_ of \_\_\_\_\_ have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items \_\_\_\_\_, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date \_\_\_\_\_, 19 \_\_\_\_\_  
Inspector Commissions \_\_\_\_\_ Nat'l Board or State and No.

1. BOILER SHELLS OR DRUMS: No. **One** Diam. **36"** Length **9** ft **0** in. Diam. Length ft. in. Diam. Length ft. in.

2. SHELL PLATES: **Firebox Quality - 55,000# T.S. - SA - 201 - Grade - A 5/16" thick**  
(For each Drum, state: Steel Manufacturer's Brand; Material Specification Number; Thickness)

3. (a) LONGITUDINAL JOINT: **Fusion Welded - Double Welded Butt**  
(Seamless, Fusion or Forge Welded, Riveted—Lap or Butt—Single, Double, Triple, or Quadruple)

(b) RIVETS: Rivet Holes (Diameter and Pitch) Eff. of Long. Joint **90** %  
(As compared to shell plates)

4. (a) TUBE SHEET: Reinforcement (No. and Thickness of Straps) Rivets (No. Rows; Mat. Spec. No.; Hole Diam. and Pitch)

(b) TUBE HOLES: Pitch (Longitudinal and Girth) Eff. of Tube Ligament %  
(Compared to shell plates)

5. GIRTH JOINTS: Rivet Holes (No. rows—Diam. and Pitch) No. of Courses **One**

6. HEADS: **Firebox Quality - 55,000# T.S. - SA - 201 - Grade - 3/4" flat**  
(Brand; Material Specification No., Thickness—Flat, Dished, Ellipsoidal—Radius of Dish—State if either head has manhole)

7. BOILER TUBES: No. **36-A-178-Str.** Diam. **2"** Length **7' 0"** Gage **13**  
(Mat. Spec. No.—Straight or Bent) (If various, give maximum and minimum lengths) (or thickness)

12. HEADER: No. Heads or Ends Hydro Test lb  
(Box or Sinuous; Mat. Spec. No.; Thickness) (Shape; Mat. Spec. No.; Thickness)

13. MUD DRUM: Heads or Ends Hydro Test lb  
(Shape; Size; Mat. Spec. No.; Thickness) (Shape; Mat. Spec. No.; Thickness)

14. (a) WATERWALLS: Headers, No. Heads or Ends Hydro Test lb  
(Shape; Size; Mat. Spec. No.; Thickness) (Shape; Mat. Spec. No.; Thickness)

(b) TUBE HOLES: Tubes Gage Heating Surface sq ft  
(Diam. and Pitch) (Diam. Length; Mat. Spec. No.) (or thickness)

15. (a) SUPERHEATER HEADERS, No. Heads or Ends Hydro Test lb  
(Shape; Size; Mat. Spec. No.; Thickness) (Shape; Mat. Spec. No.; Thickness)

(b) TUBE HOLES: Tubes Gage (or thickness)  
(Diam. and Pitch) (Diameter; Length; Material Specification No.)

Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-28 L/I	Dist. Tubes to Shell	Area to Be Stayed	Max. S.W.P.
(a) F. H. above tubes										
(b) R. H. above tubes										
(c) F. H. below tubes										
(d) R. H. below tubes										
(e) Through below tubes										
(f) Dome braces										

17. STAY BOLTS: Pitch Max. S.W.P.  
(Material Specification No.; Diameter; Size Telltale; Net Area) (Hor. or Vert.)

18. (a) DOME: Diam. Longitudinal Seam Eff. % How secured to shell  
(Mat. Spec. No.; Thickness) (Seamless, Fusion or Forge W.; Riveted—Lap or Butt—S, D, T, Q) (Std. Nozzle—Riveted; S, D, T)

(b) OPENING IN SHELL: Head  
(Diameter—Area of Reinforcement and Riveting) (Shape; Radius of Dish; Material Specification No.; Thickness)

19. (a) FURNACE: No. Size Length, each Section Total in. Type  
(Int. Diam. or L x W x H) (Plain, Adamson, or Corr.)

(b) SEAMS: Type Location  
(Seamless, Fusion or Forge W., Riveted, Lap, or Butt) (Seam)

20. OPENINGS: (a) Steam **One 2" N. Compl.** (b) Safety Valve **One 2 1/2" N. Compl.**  
(No., Size, and Type of Nozzles or Outlets) (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff **One 2" N. Compl.** (d) Feed **One 1 1/2" N. Compl.**  
(No., Size, Type, and Location of Outlets) (No., Size, Type, and Location of Connections)

(e) Manholes: No. Size Location  
(How Reinforced)

(f) Handholes: No. Size **3-4** Location **(1-RN)(3 1/2" (1))**  
(How Reinforced)

21. FUSIBLE PLUG (If Used): Boiler Supports: No. Hangers or Lugs; Riveted or Welded  
(No.; Diam.; Location; Mfrs. Stamp)

22. FUSION WELDING Complies With Paragraphs: **P61 to P96 inc. and Sec. IX of Code**

23. BURSTING PRESSURE: **851** psi Max. S.W.P. **150#** psi F.S. **5.6** Heating Surface **123** sq ft  
(Indicate Weakest Part) (Total)

24. HYDROSTATIC TEST: (a) **150** lb (b) **150** lb (c) **225** lb  
(Welded Drums) (Riveted Drums) (Completed Boiler)

# EXEMPTION CERTIFICATE (CONSTRUCTION CONTRACT)

THE GREAT LAKES STEEL & TANKER CO.  
Identification of Contract as it  
appears on orders to be exempted.  
HAMILTON AT 200 STREET  
FR. 5365 CLEVELAND, OHIO

The undersigned hereby certifies that the articles of tangible personal property purchased under this certificate were purchased for incorporation into:

- ( ) A structure or improvement to real property under a construction contract with the State of Ohio or a political subdivision thereof.
- ( ) A structure or improvement to real property under a construction contract with the United States Government or one of its agencies.
- ( ) A house of public worship or religious education.
- ( ) A building used exclusively for charitable purposes under a construction contract with a non-profit organization operated exclusively for the relief of poverty, the improvement of health through the alleviation of illness, disease or injury, or the promotion of education by an institution of learning which maintains a faculty of qualified instructors, teaches regular continuous courses of study and confers a recognized diploma upon completion of a specific curriculum.
- ( ) A structure or improvement to real property which is accepted for ownership by this state or any of its political subdivisions at the time of completion of such structures or improvements.
- ( ) A structure or improvement to real property which is accepted for ownership by the United States Government or one of its agencies.
- ( ) A structure or improvement to real property outside this state.

This certificate shall be considered a part of each order for the specific contract and shall be retained by the vendor. The certificate must be signed by both the contractor and the contractee.

Signed \_\_\_\_\_

Signed \_\_\_\_\_

By \_\_\_\_\_

By \_\_\_\_\_

Title \_\_\_\_\_

Title \_\_\_\_\_

Address \_\_\_\_\_

Address \_\_\_\_\_

Date \_\_\_\_\_

Date \_\_\_\_\_

(Prime contractor)

(Contractee)

Signed \_\_\_\_\_

Show name of political subdivision if improvement is to be accepted by one.

By \_\_\_\_\_

\_\_\_\_\_

Title \_\_\_\_\_

\_\_\_\_\_

Address \_\_\_\_\_

Date \_\_\_\_\_

\_\_\_\_\_

(Sub contractor)

# Notice of Certificate Fee Being Due (1)

OWNER OR OPERATOR Chemical Service Co.	STATE NO. 133266
LOCATION OF BOILERS 128 Locust St., Elyria, Ohio	

An internal inspection of your boiler or boilers was made on.....December 30, 1965, the Inspector reporting that provisions were not made at that time to provide him with the Ohio Certificate Fee. Attention is called to the fact that the Law requires the fee must be collected before the certificate can be issued. You will, therefore, please forward to this office the fee of \$6.00 for each boiler inspected on the said day, making a

TOTAL OF \$6.00 DOLLARS	DATE OF FIRST NOTICE January 5, 1966
----------------------------	---

Make Check or Money Order Payable to Department of Industrial Relations, State of Ohio

**IMPORTANT**  
SEE OTHER SIDE

Mail to  
The Hartford Steam Boiler Inspection and Insurance Co.  
610 EUCLID AVENUE, CLEVELAND, OHIO 44114

1097E-1

Please Return this Notice with your Remittance



**MEMORANDUM**

On receipt of fee covered by this notice it will be promptly forwarded by us to the Department of Industrial Relations, together with the Inspector's report, and certificate will be sent direct to you by the Department of Industrial Relations at Columbus, Ohio.



THE HARTFORD STEAM BOILER  
INSPECTION and INSURANCE COMPANY  
HARTFORD • CONNECTICUT 06102

WILLIAM B. MOUNT  
*Manager*

C. M. PICKETT  
*Chief Inspector*

CLEVELAND OFFICE  
610 EUCLID AVENUE  
CLEVELAND, OHIO 44114

January 5, 1966

REPORT OF INSPECTION

DATE OF INSPECTION December 30, 1965  
LOCATION 128 Locust St., Elyria, Ohio  
INSPECTOR G. M. Javor

Sellers Horizontal Tubular Boiler - No. 1-133266  
Located: Boiler Room  
Inspected externally while in service.

No conditions were observed that require attention at this time.

Yours very truly,

*C. M. Pickett*  
Chief Inspector

JEM:DA

*Paid \$6.00  
1/10/66  
Chk. # 156*

TO

Chemical Service Co.  
P. O. Box 375  
Elyria, Ohio